



CITY OF CONROE

Est. 1904

Public Works Street Department
City of Conroe
401 Sgt. Ed Holcomb Blvd.
Conroe, Texas 77304

ADDENDUM NO. 1

DATE ISSUED: June 7, 2018

PROJECT NAME: Storage Building and Sign Building

PROJECT NO.: RFP # 523-2018

This revision shall be considered part of the contract documents for the above named project and shall be incorporated integrally with the previously issued documents. Wherein provisions of the revisions differ from the provisions of the original documents and/or the provisions of previously issued addendum, the provisions of this revision shall govern and take precedence.

Clarification:

- A2.0 Foundation Plan: Notes 1 and 2 will use #4 Rods @ 12" O.C.E.W . #3 Rods will NOT be excepted
- A5.0 (10) 1- Hour Fire Wall Section: call's out to use 2x4 #2 S.Y.P Studs @ 16" O.C., Metal studs of equal structure and strength will be allowed.

End of Addendum No. 1

Kristina Colville, CPPO
Purchasing Manager